

KMB systems, s. r. o.


Dr. M. Horákové 559, 460 06 Liberec 7, Czech Republic E-mail: kmb@kmb.cz, Web: www.kmb.cz

Operating Manual for

THYRISTOR SWITCHING MODULES

KATKA 80T 400

version 2.0



The complete and most actual version of this manual is available online at http://www.KMB.cz/

Contents

1	App	lications	3				
2	Connections						
	2.1 Connection of Fan supply voltage to KATKA 80						
	2.2 Internal Wiring of KATKA 80T 400						
	2.3 Installation of KATKA into cabinet						
	2.4	Connection of Load	5				
		2.4.1 1-phase delta connected capacitors (400 V \div 440 V systems)	6				
		2.4.2 3-phase delta connected capacitor (400 V systems)	7				
		2.4.3 1-phase star connected capacitors	8				
	2.5	Connection of Control Signal to KATKA 80T 400	9				
3	Mec	hanical Dimensions	9				
1	Technical Parameters 1						
5	Ordering Diagram						
3	Acc	essories	11				
	6.1	Discharge resistors	11				
	6.2	ZP 24 auxiliary power supply	11				
7	Mai	ntenance, Service, Warranty	12				

1 Applications

KATKA 80T 400 series of thyristor switching modules have been designed especially for switching power factor correction capacitors in rapid reactive power compensation (up to 20 control interventions in one second) in conjunction with fast power factor controllers of the **NOVAR** series. They can, of course, be also used in other applications where contact-less load switching is required.

The modules are designed to switch a star- or delta-wired, symmetric or asymmetric, capacitive, resistive or inductive load in a 400V/230V (440V/250V) system. Load is connected under **near-zero voltage** (typically 5V) across the switching device and disconnected on zero-cross current.

The benefits of contact-less switching are:

- long life (high number of connections and disconnections)
- reduced current and voltage interference (connection and disconnection at near-zero power)
- fast connection and disconnection
- no switching noise

These benefits are demanded especially at following sectors:

- Welding Plants
- Presses, mills
- Windturbines
- Elevators
- Cranes
- places sensitive to harmonic distortions

2 Connections

2.1 Connection of Fan supply voltage to KATKA 80

KATKA 80 modules includes thermostat-controlled fan for forced cooling and thermal protection. Auxiliary voltage for fan on modules with active cooling (KATKA 80) is connected to terminals L and N (fig. 1a). Terminal LT is output of thermostat. Fan can be permanently turned on by connecting terminal L to LT (fig. 1b). You can also check its status on LT terminal.




Figure 1: Connection of fan supply voltage to KATKA 80

2.2 Internal Wiring of KATKA 80T 400




Figure 2: Internal wiring

2.3 Installation of KATKA into cabinet

During normal operation, modules produce great amount of heat. Therefore it's necessary to provide sufficient air flow in the cabinet (holes in bottom and top of the cabinet) and sometimes also use of active cooling (use of fan) might be necessary. Modules have to be installed vertically to allow air to flow through heatsink from bottom to top. Ambient temperature (air provided for cooling of the module) should be kept bellow 45°C.

When installing multiple rows of modules in one cabinet each row should be staggered or heat deflectors should be used. Air coming out of the module is very hot and might have negative effect to module directly above. Modules should be installed to higher levels so hot air can escape cabinet as soon as possible.




Figure 3: Installation example

2.4 Connection of Load

When using power factor correction capacitors, implementation of **detuned power factor correction is highly recommended**, otherwise an inductance of at least 12 µH must be wired in series with the switch to prevent thyristor damage by reducing speed of current rise. A detuning reactor also expands life of power factor correction capacitors and improves control accuracy. The modules incorporate class C over-voltage protection varistors. It is further recommended that a class B, 50 kA, lightning current protection device should be installed in the power lead.

2.4.1 1-phase delta connected capacitors (400 V ÷ 440 V systems)

Using this connection you get highest possible switching rate of all connections. Each capacitor have its own switch and is not overcharged while disconnected. This allows almost imediate reconection. Filter reactor can be connected before thyristor module, like with standard detuned PFC (fig. 4a). But it's also possible to connect reactor in series with capacitors (fig. 4b) which leads to smaller reactor.




Figure 4: 3 single phase delta connected capacitors

	System Voltage	Max. step output	Current/phase
KATKA 80T 400	400V	80 kvar	67 A
	440V	88 kvar	67 A

Table 1: Maximum allowed power

NOTE:

This connection is suitable mainly for rapidly changing loads where there is not enough time for discharging of capacitors. Great example are welding plants.

2.4.2 3-phase delta connected capacitor (400 V systems)

Budgetary connection with which you get fast reaction but you have to wait longer for reconnection. Capacitor gets overcharged while disconnected $(2,1\times \text{Unom})$ and it takes longer to discharge (at least to $1,4\times \text{Unom}$) to allow reconnection compared to three 1-ph capacitors.




Figure 5: 3 phase delta connected capacitor

	System Voltage	Max. step output	Current/phase
KATKA 80T 400	400V	46 kvar	67 A

Table 2: Maximum allowed power

NOTE:

This connection is suitable mainly for application where prompt reaction is necessary. Great example are cranes, elevators, presses or to decrease THD or acoustical pollution as replacement of mechanical contactors.

2.4.3 1-phase star connected capacitors




Figure 6: 1-phase star connected capacitors

	System Voltage	Max. step output	Current/phase
KATKA 80T 400	400V	3×15 kvar	67 A
	440V	$3 \times 16,7 \mathrm{kvar}$	67 A

Table 3: Maximum allowed power

2.5 Connection of Control Signal to KATKA 80T 400

The control voltage is galvanically isolated from the other circuits. The modules have a Power indicator, to indicate voltage presence, and a Control indicator to indicate closed circuit condition of the module when control voltage is applied.





Figure 7: Connection of control signal (polarity-free) to KATKA 80T 400

3 Mechanical Dimensions



4 Technical Parameters

Parameter	KATKA 20D 400	KATKA 20T 400 KATKA 20ST 400	KATKA 20T 690 KATKA 20ST 690	KATKA 80D 400	KATKA 80T 400 KATKA 80ST 400	KATKA 80T 690 KATKA 80ST 690	
nom. operating volt.	400V/230V±10%	400V/230±10% 440V/250V±10%	690V/400V±10%	400V/230V±10%	400/230±10% 440/250±10%	690V/400V±10%	
max. block. voltage		1600V					
max. oper. current	29A	22	2A	87A	67	7A	
max. rate of I rise			50A	/us			
conductor x-section		10mm ²			25mm ²		
number of switches	2	(3	2	;	3	
load character			C/R	2/L			
fan aux. voltage		-		230±10%			
fan power	-			32 VA			
aux. cond. x-section		- 2.5mm ²					
fan threshold temp.	threshold temp°C			60°C±5°C			
ctrl. volt. / current	rl. volt. / current 24 V _{DC} / 10mA (30mA for KATKA ST)						
ctrl. cond. x-section 2.5mm ²		nm²					
thermal protection		-		100°C±5°C			
overvolt. protection	С						
IP rating	IP20						
operating temp.	-20 ÷ 45°C						
oper. humidity	5 ÷ 95% non-condensing						
dimensions		122W×192H×117Dm	nm	122W×245H×157Dmm			
mass	2.05kg	2.1	5kg	3.35kg 3.45kg		5kg	

5 Ordering Diagram

	KATKA	80	Г	400
Instrument Class				
KATKA = Thyristor switching module				
Construction and power 20 = passive cooling, up to 22A (T, ST)/up 80 = active cooling, up to 67A (T, ST)/up to				
Switching method				
D = two-phase, two thyristors				
T = three-phase, three thyristors				
ST = individual switching of each phase, th	nree thyristor	S		
System Voltage				
400 = 400/230V up to $440/250V$				
690 = 690/400V (available only for option 1	[and ST)			

6 Accessories

6.1 Discharge resistors

3pcs of Auxiliary discharge resistors $33k\Omega$ / 13W are delivered with thyristor modules. Resistors are designed to be used with connection on fig. 4. Its possible to connect resistors directly to terminals of capacitors.

6.2 ZP 24 auxiliary power supply

Auxiliary supply 24 VDC is necessary for thyristor switches modules or auxiliary relays excitation. Maximum load of the supply is 100 mA, that means up to 10 thyristor modules (Model T or D) can be connected to a single supply. In case of higher load appropriate number of supplies is required. The supply is without case (IP 20) and is equipped withholders for installation on DIN 35 mm.




Figure 8: ZP24 dimensions




Figure 9: Possible connection of ZP24

7 Maintenance, Service, Warranty

Maintenance: the KATKA 80T 400 modules does not require any special maintenance during its operation but following should be respected. For reliable operation heat sink should be cleaned regularly from any debris and dust as cooling performance can be reduced otherwise. Also regular inspection of fan operation (when equipped) should be performed. It is also necessary to meet the operating conditions specified and not expose the instrument to violent handling and contact with water or chemicals which could cause mechanical damage.

Service: in the case of failure or a breakdown of the product, you should contact the supplier at their address:

KMB systems, s. r. o.
Tř. dr. M. Horákové 559
460 05 Liberec 7
Czech Republic
Tel. 485 130 314, Fax 482 739 957

E-mail: kmb@kmb.cz, Web: www.kmb.cz

The product must be in proper packaging to prevent damage during transit. A description of the problem or its symptoms must be delivered together with the product.

If a warranty repair is claimed, the warranty certificate must be sent in. In case of an out-of-warranty repair you have to enclose an order for the repair.

Warranty certificate: warranty period of 24 months from the date of purchase is provided for the instrument, however, no longer than 30 months from the day of dispatch from the manufacturer. Problems in the warranty period, provably because of faulty workmanship, design or inconvenient material, will be repaired free of charge by the manufacturer or an authorized servicing organization.

The warranty ceases even within the warranty period if the user makes unauthorized modifications or changes to the instrument, connects it to out-of-range quantities, if the instrument is damaged due to ineligible or improper handling by the user, or when it is operated in contradiction with the technical specifications presented.

Type of product:	KATKA 80T 400	Serial number:	
Date of dispatch:		Final quality inspection:	
		Manufacturer's seal:	
Date of purchase:		Supplier's seal:	